



Thermal characteristics:

Ballast losses and lamp heat radiation can lead to heat accumulation in a complete closed case. Therefore it is necessary to ensure, that the temperature at the measuring point t_c does not exceed the maximum value.

Attention:

For safety reasons disconnect the device before replacing the lamp. Terminals for protective earth not suitable for any through connection.